



Attachment B – Specifications

Revised per Addendum No.1 - 07/03/25

RFx # 3000025032

Title: *Mand Site*Fax Bid* Water Treatment Svcs

Specifications for Water/Wastewater Treatment at Iota

- Must be certified in Water/Wastewater Treatment
- Check chlorine residual twice monthly and make necessary adjustments
- Check chlorine cylinders and change as needed
- Collect wastewater samples monthly and perform analysis
- Periodically flush the Water lines as needed
- Inspect well pump, booster pump, and chlorination equipment twice monthly, service as needed
- Inspect wastewater treatment plant, twice a month
- Refill chlorinator twice a month
- Clean ultra-violet bulbs monthly
- Inspect/service lift stations twice monthly
- Provide 24-7 emergency call out service to be invoiced separately
(call outs must be accompanied by a purchase order for payment)
- Submission of monthly wastewater sample results in NetDMR to LDEQ
- Annual completion and submission of the Sewage Sludge & Biosolids Use or Disposal Reporting Form 7264



Attachment B – Specifications

Revised per Addendum No.1 - 07/03/25

RFx # 3000025032

Title: *Mand Site*Fax Bid* Water Treatment Svcs

Highway 98

Not to scale

