

**CITY OF BATON ROUGE
PARISH OF EAST BATON ROUGE
DEPARTMENT OF ENVIRONMENTAL SERVICES**

September 17, 2025

ADDENDUM NO. 4

TO: ALL BIDDERS

SUBJECT: **CENTAL WASTEWATER TREATMENT PLANT DEMOLITION PROJECT
CITY-PARISH PROJECT NO. 14-TP-MS-016D**

ORIGINAL BID DATE: Tuesday, September 16, 2025 at 2:00 PM

CURRENT BID DATE: Tuesday, September 23, 2025 at 2:00 PM

The following revisions shall be incorporated in and take precedence over any conflicting part of the original contract document:

PART 1 – UNIFORM CONSTRUCTION BID FORMS:

1. For paper sealed bidders, with reference to page UCBF 1 of 4 of Part 1, Uniform Construction Bid Forms, the Bidder shall indicate the receipt of this addendum in the space provided. For online Central Bidding bidders, an acknowledgement of this addendum will be prompted by the electronic bidding program prior to formally submitting the bid. **Failure to indicate the receipt of this addendum shall be cause for the bid to be rejected.**

PART 2 – SPECIAL PROVISIONS AND CONTRACT DOCUMENTS:

1. For paper sealed bidders, with reference to page UCBF 1 of 4 of Part 1, Uniform Construction Bid Forms, the Bidder shall indicate the receipt of this addendum in the space provided. For online Central Bidding bidders, an acknowledgement of this addendum will be prompted by the electronic bidding program prior to formally submitting the bid. **Failure to indicate the receipt of this addendum shall be cause for the bid to be rejected.**

COMMENTS AND QUESTIONS

1. Since the bid date is pushed back is it possible to schedule a day this week to get inside the site to collect a small sample of the plastic fill in the tanks? We would like to see how much it can compress to figure out how many loads we will have of the material.

The site will be made accessible to all interested bidders. The side gate at the Central Wastewater Treatment Plant located at 1104 W McKinley Street, Baton Rouge, LA 70802, will be open and accessible at 9:00 A.M. until 3:00 P.M. each day from Thursday, September 18th, 2025 until Friday, September 19th, 2025.

2. Regarding page C4 on the Central Wastewater Demo Project: the sheet gives section views for demo of the Tanks, basins, and clarifiers and under each there is an excavation depth provided. What is the relevance of that depth?

The section views on sheet C-4 are intended to show a typical section for each type of underground treatment structure, and to show an approximation of what portion of the tanks would be left in place and backfilled. The excavation depth was a request from the USACE during the permitting process and is for informational purposes only.

REVIEWED:



Obie E. Watts, III, P.E.

APPROVED:



Adam M. Smith, P.E.