JEFFERSON PARISH

CYNTHIA LEE SHENG
PARISH PRESIDENT

RENNY SIMNO

September 23, 2025

ADDENDUM # 2

Bid Number: 50-00148567 Bid Opening Date: September 23, 2025 at 2:00 PM

Bid Opening Postponed To: October 2, 2025 at 2:00 PM

Furnish Labor, Materials, and Equipment Necessary to Install Track and Field Lighting and Security Lighting Upgrade at Johnny Jacobs Playground for the Jefferson Parish Department of Parks & Recreation

QUESTIONS & ANSWERS

Question #1: Can we have clarification on exactly what fixtures are to be replaced around the track and field area for both the sports lights and the flood lights? they are more lights around the track and field than the bid is calling for?

Answer: The requesting department stated there are, 63 Sport Lights – Model # ECO-OKIA-ASP03-1250W-57K-48V-SL (for field light poles), and 22 Security Lights – Model # ECO-MFD-08-200W-48V-50K (for field light poles and bleacher poles).

Question #2: The bid also calls for dimmable drivers, will there be a control panel installed for that? if so, where will it be installed?

Answer: The requesting department stated they do not need dimmable drivers. Lights will either be 100% on or 100% off.

Question #3: It says recycling by others? so, would the lights be left on site are would the contractor be responsible for the recycling? can they just be disposed of?

Answer: The requesting department stated existing light fixtures can be disposed of.

Question #4: Can you tell us how tall the poles are?

Answer: The poles are between 60" and 80" tall.

***PLEASE REMEMBER TO ACKNOWLEDGE THIS ADDENDUM BY NUMBER ON BID SUBMISSION**

Sincerely,

Sean Dumas

Sean Dumas

Purchasing Specialist, II



CYNTHIA LEE SHENG
PARISH PRESIDENT

RENNY SIMNO

Bidders must acknowledge all addenda on the bid form. Bidder acknowledges receipt of this addendum on the bid form by indicating the addendum number listed above. Failure to list each addenda number on the bid form will result in bid rejection.

This addendum is a part of the contract documents and modifies the original bidding documents and specifications. The contents of this addendum shall be included in the contract documents. Changes made by this addendum shall take precedence over the documents of earlier date.