

October 16, 2025.

Please find the following addendum to the below-mentioned BID.

Addendum No.: 4

Bid#: 25-6-2

Project Name: Alton Water System Interconnecti

Bid Due Date: October 21, 2025

GENERAL INFORMATION:

1. This addendum forms a part of the Contract Documents and modifies Specification sections as denoted below. Acknowledge receipt of this addendum in the space provided on the Bid Form. Failure to do so may subject the Bidder to being considered non-responsive. The Bidder is responsible for disseminating this addendum to all subcontractors and material suppliers concerned. This addendum supersedes any contrary or conflicting information in any previously issued addenda. This Addendum shall be part of the Contract Documents. The following items are issued to add, delete, modify, and clarify the Contract Documents. These items shall be part of and shall have full force and effect as the Contract Documents and the cost involved shall be included in the bid price.

DAVID ALAN MARTIN

License No. 37832

- 2. Changes to Contract Specifications:
 - a. Not used.
- 3. Changes to Contract Drawings:
 - a. Drawings sheet G-504. DELETE General Note 4 and REPLACE with the following:
 - 4. All exposed piping, valves and appurtenances of the metering structure shall be insulated from freezing. The insulation shall be fiberglass or foam cell with a durable, semi-rigid plastic or aluminum jacket. The fiberglass or foam and jacket shall conform to the shape, size and layout of the valves, piping, meter and other

components attached to the metering structure. The insulation shall have a minimum insulating value of R8.

| QUESTIONS & ANSWERS: | |
|----------------------|------------|
| Not used. | |
| ATTACHMENTS: | |
| 1. Not used. | |
| | |
| | ADDENDUM 4 |

End of Addendum #4