

## ATTACHMENT C

Replacement Filters

Filters on all air-handlers (5 each) and rooftop units (3 each) shall be replaced monthly with pleated 40% minimum filters. The larger HEPA filters shall be replaced on an annual basis to be completed no later than June 30 of each year. All after-filters shall also be included.

Filter List

UNITS	FREQUENCY	FILTER TYPE	SIZE
All Air-Handlers	MONTHLY	Pleated 40% Minimum	2"
All Rooftop	MONTHLY	Pleated 40% Minimum	2"
Split Stm Heat Pump Units Type equation here.	MONTHLY	Pleated 40% Minimum	20 X 20 X 1