

INVITATION TO BID - Addendum 02		LSU	BID DUE DATE AND TIME	
BOARD OF SUPERVISORS OF LOUISIANA STATE UNIVERSITY AND AGRICULTURAL & MECHANICAL COLLEGE			10/16/2025 11:00 AM CT	
SOLICITATION RFQ-0000002630 SUPPLIER # SUPPLIER NAME AND ADDRESS 			RETURN BID TO lsubids@lsu.edu Buyer Amy Hill Bourgeois Buyer Phone Buyer Email ahill5@lsu.edu Issue Date 09/26/2025	
TITLE: Installation of New Tunnel Washer, Dump Station, and Bedding Dispenser				
Addendum 02: Notice is given to all parties that this solicitation is amended by the University as stated herein. This Addendum is hereby made an official part of this solicitation. See attached supplier inquiries and LSU responses. Bid due date extended to Thursday, October 16 at 11:00 AM CST.				
To Be Completed By Supplier				
1. _____ "No Bid" (sign and return this page only). 2. _____ My Company does not wish to receive future solicitations for this spend category. 3. Specify your Delivery: To be made within _____ days after receipt of order. 4. If applicable, Supplier's Addendum Acknowledgement/Response: As an authorized agent/signatory of the supplier, I/we acknowledge receipt of this Addendum, and _____ submit no alterations/clarifications to our original bid. _____ submit superseding revisions/clarifications to our original bid as written herein or attached hereto.				
General Instructions to Suppliers				
1. Sealed bids for furnishing the items and/or services specified are hereby solicited, and will be received by LSU Procurement at the "Return Bid To" address stated above, until the specified due date and time. 2. Read the entire solicitation, including all terms, conditions and specifications. 3. All bid information and prices must be typed or written in ink. Any corrections, erasures or other forms of alteration to unit price are to be initialed by the supplier. 4. Bid prices are to be quoted FOB LSU/Destination and inclusive of any and all applicable shipping and handling charges unless otherwise specified in the solicitation. Any invoiced delivery charges not quoted and itemized on the LSU purchase order are subject to rejection and non-payment. 5. Payment is to be made within 30 days after receipt of properly executed invoice, or delivery and acceptance, whichever is later. 6. By signing this solicitation, the supplier certifies compliance with all general instructions to suppliers, terms, conditions and specifications; and further certifies that this bid is made without collusion or fraud.				
SUPPLIER NAME			MAILING ADDRESS	
AUTHORIZED SIGNATURE			CITY, STATE ZIP	
PRINTED NAME			PHONE #	
TITLE			FAX #	
E-MAIL			FEDERAL TAX ID #	

RFQ-0000002630 – Addendum 02

Installation of New Tunnel Washer, Dump Station, and Bedding Dispenser Inquiries/Responses and Bid Due Date Extension

Inquiry 1

Bedding Dispenser: For clarity: The model listed for Better Built is a standalone unit. In the BID, under 3a. The bid states the bedding dispenser needs to be integrated with the tunnel washer. Currently, the tunnel washer is integrated with the bedding dispenser. Please clarify, if a standalone system is acceptable.

P.19 #C2a - Better Built model C202

Response 1

Yes, a stand alone is acceptable.

Inquiry 2

Connections: In some instances, PBRC will handle disconnecting utilities and others it's the suppliers responsibility. Can you clarify what PBRC will cover in this project for utility disconnect and connecting?

P.9 #1.2B Supplier told to disconnect and modify services and below it supplier to verify tie-ins and PBRC to execute. P.11 #1.1A PBRC will disconnect (electrical) services. P.12 #1.1a Supplier to provide connection to existing utilities. p.12 #1.2 Modifications to existing utility and exhaust services will be provided by PBRC.

Response 2

PBRC will provide all utility and electricity services and will disconnect and connect all equipment.

Inquiry 3

Voltage: Please confirm only 280 is available, not 480?

P.26 - Sheet E 1 of 1

Response 3

Both 280 and 480 are available.

Bid due date is hereby extended to Thursday, October 16 at 11:00 AM CST.