



Purchasing Department  
P.O. Box 9534  
Baton Rouge, LA 70813  
Phone: (225) 771-4580  
Fax: (225) 771-2026

## Addendum Number 1

December 15, 2025

### Viticulture Fields

#### SU Ag Center

Southern University and A&M College  
Baton Rouge, Louisiana 70813

**Bid # 50016-10347**

**10:30 A.M. January 9, 2026**

The following modifications to the referenced project shall be incorporated into the original specifications and/or plans. Unless a change is specifically made by addendum, the specifications and/or plans as issued shall govern.

**Bids shall be accepted in the Purchasing Department by above date and time**

**Note: Vendors are required to acknowledge receipt of this addendum on the Louisiana Uniform Public Work Bid Form**

#### **Attachment:**

- Excavation clarifications


Linda Antoine, Director of Purchasing

Date 12/15/25



# Thompson Luke & Associates, L.L.C.

10705 Rieger Road, Suite 101  
Baton Rouge, LA 70809  
225.293.9474



---

**Date of Issuance:** Monday, December 15, 2025

## Addendum # 1

**Project Name:** Southern University Viticulture Fields

**Project Address:** James L Hunt St. Baton Rouge, LA 70813

**Engineer Project No.:** 24-131

---

The following items shall be considered part of the Contract Documents for the above referenced project and shall take precedence over any conflicting statements contained therein. Revise all other notes, schedules, details, elevations, and sections as required.

### **CLARIFICATIONS:**

#### **General:**

1. In the 4 – 1.5 Acre fields, the contractor shall excavate the existing soil to a point 12" below the proposed grade of the site as shown on Sheet C1.0 – Drainage and Grading Layout. Soil meeting the specified requirements shall be imported to these fields and graded as per Sheet C1.0 – Drainage and Grading Layout so that there is 12" of the specified imported material. The excavated material shall be stockpiled on the existing property to the west of the site. The imported material shall be a sandy loam with a PH between 5.8 and 6.5. A soil report indicating the soil ingredients and PH must be submitted for approval prior to purchasing soil.

If you have any questions, please contact our office.

Thompson Luke & Associates, L.L.C.  
A Professional Engineering Company