

**CITY OF BATON ROUGE
PARISH OF EAST BATON ROUGE**

January 15, 2026

ADDENDUM NO. 3

TO: ALL BIDDERS

**SUBJECT: TERRACE AVENUE (Highland Road – Perkins Road) PROJECT
CITY-PARISH PROJECT NO. 20-EN-HC-0045**

REVISED BID DATE BY THIS ADDENDUM : Tuesday, January 27, 2026 at 2:00 P.M.

ORIGINAL BID DATE: Thursday, January 08, 2026 at 2:00 p.m.

Note: The following revisions shall be incorporated in and take precedence over any conflicting part of the original contract documents.

As of January 14, 2026 the following RFI were received and have been responded to below:

SEE THE DRAWINGS:

- **Delete sheets 102 and 104 from the plan set. As clarification, the sheets and associated work has been deleted from the project.**
- **As clarification, sidewalks shown on plan sheets 4 thru 10 shall be constructed and paid for as 4" Concrete Walk (Under Pay Item 9070304), not 5" Pervious Concrete Pavement. See Unit Price Form.**

1. On Sheet 2 of original Plans you had Item 5100105 5" Pervious Concrete Pavement but it was not on the bid form. Now that item is removed from sheet 2. Plan sheets 4-10 call out pervious concrete. Please advise what you all want. Do you want pervious and if so will you add the pay item or will this just be regular sidewalk?
 - **Item 5100105 5" Pervious Concrete Pavement has been deleted from the project and associate quantities is now included in item 9070304 (4" Concrete Walk). Pervious Concrete Pavement shown on sheets 4 thru 10 shall now be constructed as 4" Concrete Walk per section 907 of the Contract Documents.**



George Chike, P.E.
Project Manager