



"RE-BUILDING THE CITY'S WATER SYSTEMS FOR THE 21ST CENTURY"

Sewerage & Water Board of NEW ORLEANS

625 ST. JOSEPH STREET
NEW ORLEANS, LA 70165 • 504-529-2837 OR 52-WATER
www.swbno.org

Addendum No. 4

Date: 1/27/2026

Your reference is directed to **Contract Number: 2025-SWB-92 (30111)** for Suction Isolation at 12 Sewer Pumping Stations which is scheduled to open at **11:30 a.m. CST** on **February 4, 2026**, for SWBNO Mechanical Engineering Department.

This addendum provides for the following:

1. Amended response to question 13 on Addendum
2. Voluntary Meeting

1. Amended response to question 13 on Addendum
 - *Question: Will a mechanical jointed flanged adapter (Mega flange or equal) be allowed in-lieu of welding new flanges on stations without an existing spool piece?*
 - ❖ *Amended Response: Welded Flanges are not mandated. Mechanical jointed flanged adapters shall be properly supported as per manufacturer requirements. Mechanical jointed flanged adapters shall be submitted to Engineer for approval and shall have a 125 # rating or better.*
2. Voluntary Meeting
 - *January 28, 2026, 10:30 a.m. at Village D 'lest followed by Lamb and Lawrence.*

The above revisions shall be incorporated in and take precedence over any conflicting part of the original proposal documents. This addendum is hereby officially made a part of the referenced proposal.

Receipt of this addendum shall be acknowledged by inserting its number and date in the space provided on the Louisiana Uniform Public Works Bid Form.

This addendum consists of one (1) page.

*** END OF ADDENDUM ***