

**CITY OF BATON ROUGE
PARISH OF EAST BATON ROUGE
DEPARTMENT OF ENVIRONMENTAL SERVICES**

March 16, 2026

ADDENDUM NO. 1

TO: ALL BIDDERS

SUBJECT: **ANNUAL PARISHWIDE CONCRETE PAVEMENT RESTORATION PROJECT
CITY-PARISH PROJECT NO. 26-CR-MS-0001**

BID DATE: Thursday, March 19th, 2026 at 2:00 PM

The following revisions shall be incorporated in and take precedence over any conflicting part of the original contract document:

PART 1 – UNIFORM CONSTRUCTION BID FORMS:

1. For paper sealed bidders, with reference to page UCBF 1 of 2 of Part 1, Uniform Construction Bid Forms, the Bidder shall indicate the receipt of this addendum in the space provided. For online Central Bidding bidders, an acknowledgement of this addendum will be prompted by the electronic bidding program prior to formally submitting the bid. Failure to indicate the receipt of this addendum shall be cause for the bid to be rejected.

PART 2 – SPECIAL PROVISIONS AND CONTRACT DOCUMENTS:

1. For paper sealed bidders, with reference to page UCBF 1 of 2 of Part 2, Uniform Construction Bid Forms, the Bidder shall indicate the receipt of this addendum in the space provided. For online Central Bidding bidders, an acknowledgement of this addendum will be prompted by the electronic bidding program prior to formally submitting the bid. Failure to indicate the receipt of this addendum shall be cause for the bid to be rejected.

CONTRACTOR QUESTIONS AND ANSWERS

1. Please provide the LA Licensed Classification that is required to bid for this project (See LA R.S. 37:2156.2 for classifications).

All LA license classifications are acceptable for bidding on this project.

2. Request for the engineer's estimate/budget for project.

The project budget shall be released following the opening of bids.

3. The HES Concrete Pavement Items: (A) Does it have an asphalt overlay on top? (B) The specification also talks about how restoring existing traffic markers and symbols are to be included in this bid item. Does that not get accounted for under the pavement marking allowance?

The project scope of work does not include any asphalt work. The pavement marking allocation pay item is intended for use in situations where other pay items do not already include pavement marking as apart of the measurement and payment.

4. For the temporary pavement surfacing item, the specifications call out three different situations. Is the contractor to choose if they want to use aggregate, cold mix, or steel plates? It is hard to determine what to bid if we do not know the location and speed limits. There is also a steel plate pay item. Would the contractor be paid for steel plates under both items, temporary pavement structure, and temporary steel plates?

Please refer to Table 503-1 of the Specifications for requirements on materials for temporary surface types. For the purposes of this contract, the contractor shall bid assuming that only aggregate surfacing will be used for pay item 5031000. The use of the steel plates will be directed by the owner/engineer and shall be paid using pay items 5032000 and 5032001.

5. Request for a dollar amount estimate for a typical work order to be issued on the contract. Request for a minimum dollar value of a typical work order (e.g. no work order will be lower than \$X,XXX.XX)

There will be no guarantees on minimum dollar value of each work order. A typical work order shall include five to fifteen different locations with varying quantities of concrete restoration.

REVIEWED:



Will Fishburn, P.E.



APPROVED:



Adam M Smith, P.E.