

- 1) Do the can lights need a total replacement?
  - a. **No just LED bulbs**
- 2) Will BRCC provide the Can light fixture?
  - a. **Fixture does not require replacement**
- 3) Do the track lights on the second floor get replaced?
  - a. **No they are to be removed and fasteners taken off of the grid railing**
- 4) Will BRCC provide the Trac light if required?
  - a. **See answer above (3a)**
- 5) Do the exit lights get replaced?
  - a. **No**
- 6) Will BRCC provide exist lights.
  - a. **If the question is “will BRCC provide exit lights?”, this answer is reflected in the answer above (5a)**
- 7) Will the wire molding need replacing?
  - a. **Yes, if it leads to a blank cover plate or blank covered gang box that will be removed. If it leads to active outlets it will remain.**
- 8) Will this project need a Bond? I don't see the package requiring a performance bond.
  - a. **No**
- 9) Whats the est. Budget?
  - a. **This project does not have a set budget cap.**