

## **Addendum No. 2**

Addition & Renovations Facility Planning & Management Building McNeese State University  
4406 Common Street  
Lake Charles, LA

Project No.: 19-627-01,01-107-05B-13, F.19002582, F.01004544

State of Louisiana  
Facility Planning and Control  
1201 N Third Street, Claiborne Bldg, Suite 7-160  
Baton Rouge, LA 70802

### **TO ALL CONTRACTORS:**

This Addendum is hereby made a part of the Contract Documents dated March 15, 2026 and prepared by Brossett Architect, LLC.

The following items shall be considered part of the Contract Documents and shall be included in the same upon executions of the Contract. Changes made by Addenda take precedence over information published at an earlier date. Any changes, which may affect construction or proper installation of materials, equipment or structures, not specifically mentioned in this addendum, shall be brought to the attention of the Architect before submitting bid. Otherwise, such conditions, if found later to exist, must be worked out in an acceptable manner at no additional cost to the Owner.

It is understood and agreed that the following alterations, changes and/or omissions shall be made in the Plans and the Specifications, as now drawn and written, and that such alterations, changes and/or omissions shall be incorporated in the project during construction. Unless such an alteration, change and/or omission is specifically mentioned in this addendum, the plans and specifications as now drawn and written, shall govern in all respects.

Acknowledge receipt of this Addendum on the Bid Form.

Bidders are advised to call attention of all sub-bidders and suppliers to all information and changes which may affect their work.

This addendum consists of a total of 2 pages.

### **PART 1 – Drawing Modifications**

1. A2.3-3/5: Hat channels to be 16 ga.
2. A2.4-Door Schedule: Doors 104, 111, 112, 113, 115, 116, 117B, 118, 119 and 114 are existing doors to remain.
3. A6.1-1: Scale of drawing is ¼"= 1'-0" in lieu of as noted.
4. A6.2-Reflected ceiling plan: Provide new 8" x 16 ga ceiling joists at 16" o.c. for new gyp bd ceilings in Rooms 109 and 110.
5. Reference all Mechanical and Plumbing Sheets: It is the intent that the Facility Management Building and adjacent Shop shall remain occupied and in service for the duration of the addition

