



ST. TAMMANY PARISH

MICHAEL B. COOPER
PARISH PRESIDENT

April 27, 2026

Please find the following addendum to the below-mentioned BID.

Addendum No.: 3

Bid#: 26-20-2

Project Name: Goldenwood Drive Drainage

Bid Due Date: Tuesday, May 5, 2026

QUESTIONS & ANSWERS:

Question 1. Will the Owner specify design thicknesses for the pipe liners, or specify a standard means of calculating the thickness (i.e. per ASTM-F1216 or per ASTM-F3706)?

Answer 1. The thickness should be between 15 mm and 24.5 mm, depending on burial depth.

Question 2. Are there any water fees associated with this project?

Answer 2. It is the Contractor's responsibility to provide water if needed.

Question 3. Are any permits required for this project?

Answer 3. No.

Question 4. Is contractor-provided resident notice required, and if so, what are the requirements?

Answer 4. Yes, make residents aware of work being performed in front of homes.

Question 5. Are any maps, plans, or other reference documents available for this project?

Answer 5. No, please use the street names provided to identify the location.

End of Addendum # 3