



"RE-BUILDING THE CITY'S WATER SYSTEMS FOR THE 21ST CENTURY"

Sewerage & Water Board OF NEW ORLEANS

625 ST. JOSEPH STREET
NEW ORLEANS, LA 70165 • 504-529-2837 OR 52-WATER
www.swbno.org

Addendum No. 4

Date: 4/30/2026

Your reference is directed at **Contract Number:** 2026-SWB-19 (30111) for Suction Isolation at 12 Sewer Pumping Stations which is scheduled to open at **11:30 a.m.** CST on **May 7, 2026.**
This addendum provides for the following:

1. Responses to Vendor Questions.

1. Responses to Vendor Questions.

Question 1- What is the owner's budget for this project?

- **Answer: The Engineering estimate is: \$450,000.00**

Question 2-Is builder's risk insurance required? If so, is the policy required to cover the perils of named storms and/or floods?

- **Answer: The Builder's Risk insurance requirement language is found in the General Conditions section, pg. 19 of 40, subsection 5.06, Property Insurance, No. 2. "be written on a Builder's Risk "all-risk" policy form that shall at least include insurance for physical loss or damage to the Work, temporary buildings, falsework, and materials and equipment in transit, and shall insure against at least the following perils or causes of loss: fire, lightning, extended coverage, theft, vandalism and malicious mischief, earthquake, collapse, debris removal, demolition occasioned by enforcement of Laws and Regulations, water damage (other than that caused by flood), and such other perils or causes of loss as may be specifically required by the Supplementary Conditions".**

Question 3- Please clarify the extent to which sand blasting and painting is required. Is painting only required if new spool pieces are installed? If the existing spool pieces are reused, will they need to be removed and repainted? Or will touch-up painting only be required where the pipes are cut?

- **Answer: If new steel is introduced, it must be sanded and painted as per spec. Sanding and touch-up painting are required at cuts/welds. Cleaning with a wire wheel is acceptable for replacing sand blasting.**

The above revisions shall be incorporated in and take precedence over any conflicting part of the original proposal documents. This addendum is hereby officially made a part of the referenced proposal. Receipt of this addendum shall be acknowledged by inserting its number and date in the space provided on the Louisiana Uniform Public Works Bid Form.

This addendum consists of one (1) page

***** END OF ADDENDUM *****