

CITY OF BATON ROUGE
PARISH OF EAST BATON ROUGE

June 1, 2026

ADDENDUM NO. 2

TO: ALL BIDDERS

SUBJECT: GOODWOOD BLVD SIDEWALKS & BIKE PATHS (Airline Hwy – Sharp Rd) PROJECT
CITY-PARISH PROJECT NO. 24-EN-HC-0002

ORIGINAL BID DATE: THURSDAY, JUNE 4, 2026 at 2:00 p.m.
THE BID DATE IS NOT REVISED BY THIS ADDENDUM

The following revisions shall be incorporated in and take precedence over any conflicting part of the original contract documents.

REQUESTS FOR INFORMATION AND RESPONSES

As of June 1, 2026 the following requests for information was received and is hereby addressed as follows:

1. For the median area on Goodwood, should the trees be trimmed or removed?
 - *The trees are to remain. Only tree trimming in the median should take place where sidewalk is being installed and if there are any limbs in the 7' vertical clearance, as detail 2 on sheet 3 shows. That detail should be followed where any sidewalk is installed.*
2. Should the trees on the bike paths on both sides of the boulevard be trimmed?
 - *Plans include trimming within vertical clearance of the sidewalk only.*



George Chike, P.E.
Project Engineer