



# JEFFERSON PARISH

DEPARTMENT OF PURCHASING



CYNTHIA LEE SHENG  
PARISH PRESIDENT

RENNY SIMNO  
DIRECTOR

June 24, 2026

**ADDENDUM #2**

**Bid Number: 50-00150109**

**Bid Opening Date: July 2, 2026**

**Two (2) Year Contract for Decorative & Landscape Lighting Maintenance for the Eastbank & Westbank of Jefferson Parish for the Parkways Department**

---

**Question and Answer:**

1. **Question:** Could you please advise what load rating or tier rating Jefferson Parish is requiring for these underground enclosures and lids? For example, are these intended to meet a specific ANSI/SCTE or manufacturer rating such as Tier 5, Tier 8, Tier 15, or another classification?

**Answer:** The boxes can be Tier 8 or higher.

Sincerely,

Stacey Champagne, Purchasing Specialist II  
Jefferson Parish Purchasing Department

**Bidders must acknowledge all addenda on the bid form. Bidder acknowledges receipt of this addendum on the bid form by indicating the addendum number listed above. Failure to list each addenda number on the bid form will result in bid rejection.**

**This addendum is a part of the contract documents and modifies the original bidding documents and specifications. The contents of this addendum shall be included in the contract documents. Changes made by this addendum shall take precedence over the documents of earlier date.**