



JEFFERSON PARISH

DEPARTMENT OF PURCHASING



CYNTHIA LEE SHENG
PARISH PRESIDENT

RENNY SIMNO
DIRECTOR

JUNE 16, 2026

ADDENDUM #1

Bid Number: 50-00150163

Bid Opening Date: July 16, 2026

Labor, Materials & Equipment Necessary to Provide and Install Shelter at the Martin Luther King Playground
for the Jefferson Parish Department of Recreation

Question and Answer:

1. **Question:** Foundation details: Will the Parish provide the manufacturer's foundation/footer detail (size, depth, and reinforcement) for bidding purposes, or are bidders to base footer quantities solely on the awarded manufacturer's engineered drawings after award?

Answer: As per manufacturers and engineer requirements per specifications section A #8.

2. **Question:** Engineered drawings: Please confirm the one (1) set of engineered stamped drawings is to be sealed by a Louisiana-licensed professional engineer.

Answer: One set of engineered stamp drawings per specification section A #6.

3. **Question:** Slab/footer configuration: Are the four (4) concrete footers to be integral with (monolithic to) the 22' x 22' slab, or cast as separate isolated footings below the slab?

Answer: Please refer to shelter design manufacturer recommendation.

4. **Question:** Sidewalk location: Please confirm the location and tie-in point of the 10' L x 5' W sidewalk relative to the new slab, and the location of the 3' x 3' garbage pad.

Answer: This will be discussed at the pre-construction conference once the bid is awarded.

5. **Question:** Wind design criteria: Please confirm the design wind speed/risk category the shelter engineering must meet for this site (2400 Lester St., Harvey, LA 70058).

Answer: IBL 2021 Wind load 145 mph gust cat. C



JEFFERSON PARISH

DEPARTMENT OF PURCHASING



CYNTHIA LEE SHENG
PARISH PRESIDENT

RENNY SIMNO
DIRECTOR

6. **Question:** Color selection timing: Will roof and beam color selections be made at the pre-construction conference so shelter fabrication can be released immediately upon Notice to Proceed, given manufacturer lead times?

Answer: The color will be selected during the pre-construction conference.

7. **Question:** Utilities: Is any electrical service to the shelter included in this scope, or is the standard electrical access hole in the column base the only electrical provision required?

Answer: No electrical service is required.

8. **Question:** Site access: Please confirm equipment access route to the shelter location and any restrictions on staging within the playground.

Answer: This will be discussed during the pre-construction conference.

Sincerely,

Stacey Champagne, Purchasing Specialist II
Jefferson Parish Purchasing Department

Bidders must acknowledge all addenda on the bid form. Bidder acknowledges receipt of this addendum on the bid form by indicating the addendum number listed above. Failure to list each addenda number on the bid form will result in bid rejection.

This addendum is a part of the contract documents and modifies the original bidding documents and specifications. The contents of this addendum shall be included in the contract documents. Changes made by this addendum shall take precedence over the documents of earlier date.