



ST. TAMMANY PARISH

MICHAEL B. COOPER
PARISH PRESIDENT

July 15, 2026

Please find the following addendum to the below-mentioned QUOTE.

Addendum No.: 2

Quote #: 26-20-1

Project Name: Lafitte St Drainage

Quote Due Date: *NEW TUESDAY, JULY 28, 2026*****

GENERAL INFORMATION:

1. Please note that the Quote opening has been pushed to **Tuesday, July 28, 2026**. Time and location remain the same. The inquiry deadline is **Tuesday, July 21, 2026**. The addendum deadline is **Thursday, July 23, 2026**.
2. Please remove Attachment G – Layout - Revised and replace it with Attachment G- Layout – Revised – Addendum No. 2 (attached).

QUESTIONS & ANSWERS:

Question 1. After reviewing the plans, it appears that the quantities for the 24-inch RCP and the 30-inch RCP may have been switched. Based on our review, it seems the quantity shown for the 24-inch RCP should apply to the 30-inch RCP, and vice versa. Could you please confirm whether the quantities have been mixed up, or if we are interpreting the plans incorrectly?

Answer 1. Please note that the unit price form and the specifications were correct in quantities. However, Attachment G – Revised had an incorrect note. Please refer to General Information #2.


ATTACHMENTS:

1. Attachment G- Layout – Revised– Addendum No. 2.pdf

End of Addendum # 2

Attachment G - Revised– Addendum No. 2

General notes:
:All catch basin inlet inverts shall be lower than the surrounding ground elevation by no more than 2 inches. Catch basin locations and elevations shall be field fit.
:All sewer tie ins shall be at no direct pay.
: Pipe lengths between catch basins shall be field fit, depending on the actual catch basin locations.



--	--

Rev. No.	Date	Description

St. Tammany Parish
Department of Public Works
P.O. Box 628 Covington, La 70434
Phone: (888) 888-2352
E-mail: enr@stpn.org



Project No.	Sheet
Date	
Scale	
Drawn By	

HWY 59

Lafitte Street

Orleans Street

Lafitte Street

HWY 59

Existing 48" RCPA
invert is 7.31

Existing 30" CPP to
remain

Existing 30" CPP to
remain. Invert is 8.26

Existing 18" CPP to
be removed and
replaced with 32" of
30" RCPA

Existing 18" CPP to
be removed and
replaced with 24" of
30" RCPA



St. Tammany Parish
Department of Agriculture
P.O. Box 638 Covington, LA 70434
Phone (504) 886-2552
Email: info@aginfo.org

