



ST. TAMMANY PARISH

MICHAEL B. COOPER
PARISH PRESIDENT

July 30, 2026

Please find the following addendum to the below-mentioned BID.

Addendum No.: 1

Bid#: 26-38-2

Project Name: One Time Purchase for Blowers

Bid Due Date: Wednesday, August 5, 2026

QUESTIONS & ANSWERS:

Question 1. Could you please clarify the following for the blower packages?

- Operating flow rate required, in SCFM or ACFM
- Operating discharge pressure or inlet vacuum
- Whether the units will be installed indoors or outdoors
- Application/service: what the blowers are used for and whether they are moving air or any special gas
- Any special constraints or design specifications beyond the listed 7.5 HP / 1750 RPM / 460V 3-phase / 60 Hz TEFC motor, silencers, acoustically insulated enclosure, and 6 PSIG relief valve

Answer 1.

- The Parish does not have this information at this time.
- 5PSI
- Installation will be outdoors.
- Moving air for a packaged wastewater treatment plant.
- There are no special requirements

Question 2. What is the required operating performance for each blower, including CFM at the required discharge pressure?

Answer 2. Please refer to Answer # 1 bullet point #2.



ST. TAMMANY PARISH

MICHAEL B. COOPER
PARISH PRESIDENT

Question 3. Is there a maximum sound requirement? If so, please provide the required dBA level and measurement distance.

Answer 3. 70DBA @ 30'

Question 4. Please clarify the enclosure requirements. Would a metal stand or base with a fiberglass top/cover be acceptable, or is a fully enclosed, sound-attenuated package package similar to a Roots EasyAir package required?

Answer 4. Fully enclosed, sound-attenuated package metal/steel.

End of Addendum # 1