



PURCHASING DEPARTMENT

August 20, 2026

Addendum #2

50018-270002

Residential Life Kitchenette Renovation's

This Addendum No. 2 forms a part of the Invitation for Bids (IFB) and Contract Documents and modifies the original IFB and Contract Documents as stated herein. All provisions not specifically modified by this Addendum shall remain in full force and effect.

APPROVED SPECIFICATIONS AND CLARIFICATIONS

ITEM 1 – Approved Manufacturer

AFX is approved as an acceptable manufacturer for the ceiling light fixtures.

ITEM 2 – Plumbing Clarification

The required vent piping for the new sinks at both dormitory buildings shall be installed exposed on the exterior of the buildings. The piping shall penetrate the exterior wall as high as possible. All exposed PVC piping shall be painted to blend with the existing brick color.

ITEM 3 – Fire Marshal Release

The Fire Marshal Release is attached and incorporated into this Addendum for reference.

Erin Walker
Director of Purchasing
Grambling State University



LOCATION		DATE
PREPARED BY		QUANTITY
COMMENTS		FIXTURE TYPE
CATALOG NUMBER		

Eon Round LED Surface Mount Disc Light EONF Series

Features

This ultra low profile design provides a dramatic look and features an edge-lit light panel construction. Products can be used in various applications including corridors, closets, hallway, kitchen and anywhere general lighting is needed.
Indoor use only - Wall or ceiling mount.
Outdoor use only - Covered ceiling mount.



Construction

Edge-lit technology housing is injection molded with aluminum backplate.
Snap-in bracket.
Mounts to standard junction box (not included).
Power supply connections must be made inside junction box.

Finish

Choose from Black, White or Satin Nickel (14" ONLY)

Diffuser

White acrylic diffuser.

Electrical

Input 120 VAC 60 HZ.
Compatible with residential (TRIAC/ELV) dimmers.

LED

Fixture includes a LED modules capable of producing:
7W = 460 delivered lumens
12W = 800 delivered lumens
17W = 1100 delivered lumens
24W = 1740 delivered lumens
28W = 2000 delivered lumens
Adjustable Choice 2700K, 3000K, 3500K, 4000K, 5000K (CCT).
Rated for 50,000 Hrs. 90 CRI.

Certification

cETLus listed
Title 24/JA8 Compliant
Wet location rated for indoor use. Outdoor wet location rated for covered ceiling mount applications ONLY (not recommended for any other outdoor use).
Suitable for use in clothes closets when installed in accordance with the NEC 410.16 spacing requirements.

Warranty

Limited warranty: This fixture is free from defects in materials and workmanship for a period of 5 years from date-of-purchase.

Specifications and dimensions
subject to change without notice.



EASY
TWIST-N-LOCK
INSTALLATION



Ordering Information:

Black	Satin Nickel	White	LED	Delivered Lumens	Adjustable CCT	DIA.	D
EONF05LAJD1BK	-	EONF05LAJD1WH	7W	460	2700K/3000K/3500K/4000K/5000K	5"	7/8"
EONF07LAJD1BK	-	EONF07LAJD1WH	12W	800	2700K/3000K/3500K/4000K/5000K	7"	7/8"
EONF09LAJD1BK	-	EONF09LAJD1WH	17W	1100	2700K/3000K/3500K/4000K/5000K	9"	7/8"
EONF11LAJD1BK	-	EONF11LAJD1WH	24W	1740	2700K/3000K/3500K/4000K/5000K	11"	7/8"
EONF14LAJD1BK	EONF14LAJD1SN	EONF14LAJD1WH	28W	2000	2700K/3000K/3500K/4000K/5000K	14"	7/8"

Office of State Fire Marshal

-Independence Blvd, Baton Rouge, LA 70806 | (225) 925-4911 (800) 256-5452 Fax (225) 925 8181 4241



Fredrick Carr

Owner

514 Rwe Jones Drive, Grambling, LA 71245
3182742504

carrf@gram.edu

Review Status

Review status Released
Date Completed 07/30/2026
Review Type Architectural Review
Applicable Code Edition 2021

Project Information

Project Number AR-26-019967
Description Interior Renovation to kitchenette in Robinson Hall
Project Name GSU Kitchenette-Interior Renovations to Robinson Hall
Address 403 Main Street, Grambling, LA 71245
Jurisdiction Lincoln
Ownership State Owned/Leased
Estimated Cost \$50,000
Within City Limits No

Building Characteristics

High Rise Building
Number of Stories 2
Project on which Floor(s) 1
Area under review 300 sq ft.
Total allocated area 300 sq ft.
Separation type

Review Type Details

Classification of Work

Construction Type: Alteration and Addition
Primary Building Construction (IBC): V-B / V (000)
Additional Features: Sprinkler System - 13, Fire Alarm System, University/College

Scope:

Renovation / Addition

Alteration Level: Alteration Level 2 (<50% of the buildings physical value)
Date of Bldg (C):
Existing Sq Ft: 300 sq ft.

Ren/Add Types:
Date of Bldg (R):
Addition Sq Ft:

Renovation Sq Ft: 300 sq ft.

Prev Occupancy:

Gen Inst Level:

Occupancy Breakdown

SF 300

Business

300 SF

Individuals Involved In This Project

2

Fredrick Carr • Owner • 514 Rwe Jones Drive, Grambling, LA 71245

LAUREN F. MARCHIVE • Professional of Record • 2800 YOUREE DR. STE. 310, SHREVEPORT, LA 71104

Review Completed By

Name Jeff Gonsoulin

Badge No. 694

signature



Cautionary Codes

ADA-ABA GENERAL:

1. ADA-ABA 202.3

- If existing elements, spaces, or common areas are altered, then each such altered element, space, feature, or area shall comply with the accessibility requirements for NEW construction.

2. LRS 40:1731

- LRS 40:1731-(Effective 10/01/11) Provide access for persons with disabilities in accordance with the ADA-ABA Accessibility Guidelines, July 23, 2004 (also known as the 2010 Standards). This does not include a review for compliance with the Federal Americans with Disabilities (Civil Rights) Act of 1990. Compliance with state regulations and requirements does not guarantee compliance with federal law. NOTE: As per ADA -ABA 2004, Section F103, Office of State Fire Marshal equivalency determinations are not valid for facilities that are designed, constructed, altered, or operated with federal funds, or leased by a federal agency. The authority having jurisdiction over such appeals is the administrator of the General Services Administration (GSA). Particular observations and paragraph references are noted as follows:

AR - SCOPE OF WORK:

3. NOTES:

- This review applies to new work indicated in the drawings and does not apply to existing non-conforming conditions.

4. SCOPE OF WORK:

- Scope of Work: This review applies to A NEW ADA COMPLIANT KITCHENETTE FOR A COLLEGE CLASSROOM. NO OTHER CHANGES ARE PROPOSED TO THE BUILDING.

FIRE PROTECTION SYSTEM - COOKING:

5. IMC 507.1.2

- Residential cooking equipment in KITCHENETTE shall only be used for warming or limited cooking that produces no grease-laden vapors. Otherwise, cooking equipment shall be protected in accordance with NFPA 96. (See NFPA 96:1.1.5 and ANNEX statement A.1.1.5). (NOTE: Type "K" portable fire extinguishers shall NOT be installed in areas housing electrical cooking appliances, unless the appliance electrical system is shunted upon activation of an approved hood suppression system).

FIRE PROTECTION SYSTEM - FIRE EXTINGUISHERS:

6. LAC 55:V:303.E

- Provide listed portable fire extinguishers in accordance with NFPA 10. (Refer to Appendix E for distribution information.)
Classification:
 - Class A fires: fires in ordinary combustible materials, such as wood, cloth, paper, rubber and many plastics. Travel distance to a fire extinguisher shall not exceed 75 feet.
 - Class B fires: fires in flammable liquids, combustible liquids, petroleum greases, tars, oils, oil-based paints, solvents, lacquers, alcohols and flammable gases. Travel distance to a fire extinguisher shall not exceed 30 feet for Class B fires (liquids). (May be increased to 50 feet for

Light (low) Hazard fires with 10-B extinguisher, for Ordinary (moderate) Hazard fires with 20-B extinguisher, and for Extra (high) Hazard fires with 80-B extinguisher). See Table 10:6.3.1.1.

- Class C fires: fires that involve energized electrical equipment. Travel distance to a fire extinguisher shall not exceed 75 feet.
- Class D fires: fires in combustible metals. Travel distance to a fire extinguisher shall not exceed 75 feet.
- Class K fires: fires in cooking appliances that involve combustible cooking media (vegetable or animal oils and fats.) Travel distance to a fire extinguisher shall not exceed 30 feet for Class K fires (cooking appliances). See NFPA 10:6.6.

7. NFPA 10:6.1.3

- a. Fire extinguishers shall be conspicuously located where they will be readily accessible and immediately available in the event of fire. Locate portable fire extinguishers along normal paths of travel, including exits from areas.
- b. - Fire extinguishers shall not be obstructed or obscured from view.
- c. - Top of fire extinguisher, having a gross weight less than 40 lb, shall be not more than 5 feet above the floor; if gross weight 40 lbs or greater, 3-1/2 feet above the floor. The bottom of a hand portable fire extinguisher shall not be less than 4" above the floor.

GENERAL COMMENTS:

8. LRS 40:1730.49.B and 40:1563

- a. REVIEW FOR COMPLIANCE WITH THE LIFE SAFETY AND FIRE PROTECTION REQUIREMENTS OF THE INTERNATIONAL BUILDING CODE ARE INCLUDED IN THIS REVIEW. Contact the building official of the applicable political subdivision to coordinate compliance with the complete requirements of the Louisiana State Uniform Construction Code (LSUCC). LRS 40:1730.23 mandates the enforcement of the LSUCC codes by municipalities and parishes in Louisiana, as described by LRS 40:1730.28. LRS 40:1730.23.H permits a parish or municipality to accept determinations made by the state fire marshal as they pertain to life safety and fire protection as required by the LSUCC.

Project: Residential Life Kitchenette

PLEASE PROVIDE INFORMATION REQUESTED IN EACH SECTION

[illegible]