



Office of the Mayor-President

Purchasing Division
City of Baton Rouge
Parish of East Baton Rouge
222 St. Louis St. 8th Floor Room 826
P.O. Box 1471
Baton Rouge, Louisiana 70821
225-389-3259
FAX 225-389-4841
purchasinginfo@brgov.com

Philip Gore
Interim Director of Purchasing

ADDENDUM NO. 2
August 18, 2026

Your reference is directed to:

Solicitation Number: **M6321 BATON ROUGE AIRPORT RENTAL CAR GARAGE**

Scheduled to open: **August 25, 2026 11:00 am CST**

The following questions and answers are hereby officially made a part of the referenced solicitation and should be attached to the bidder's proposal or otherwise acknowledged therein.

If you have already submitted your proposal and this addendum causes you to revise your original bid, please indicate changes herein and return to Purchasing prior to the bid opening in an envelope marked with the file number, bid opening date, and time. If this addendum does not cause you to revise your bid, please acknowledge receipt of the addendum by signing your name and company below and returning it in accordance with the provisions above.

abarges@brla.gov
225-389-3259 x 3273

Signature

Date

Company

M6321 BATON ROUGE AIRPORT RENTAL CAR GARAGE
Questions & Answers

Q1: Please confirm the bid bond is to be 5% of the bid amount? If not, please clarify the required percentage.

A1: The bond will be for 5%

Q2: Please confirm that the elevator closest to the terminal will be closed on all levels for the duration of the project?

A2: Yes

Q3: Can you please provide the brand or type of bearing pad that should be utilized?

A3: The bearing pads shall be 70 Durometer rubber.

Q4: Please state that awarded contractor is to remove the existing shoring and place on one location for another to pick up and remove from the site.

A4: Yes, the awarded contractor will need to remove the existing shoring and place it in a location accessible for United Restoration Preservation to recover. Beside the first-floor elevator landing should be a good location for recovery.

Q5: Please confirm that parking will be allowed on the 5th top floor of the parking garage.

A5: Yes

Q6: Please confirm that all both double T's shoring (4 shoring posts) will remain in place the entire duration of the repairs.

A6: This was addressed in Addendum #1. Yes, the 4 shoring posts shall remain for the duration of the project.