

OFFICE OF PURCHASING
O'KEEFE ADMINISTRATION BUILDING
501 City Park Avenue, Bldg 37
New Orleans, LA 70119
(504) 762-3027 FAX: (504) 762.3089
www.dcc.edu

Addendum No: (1)

Bid No: 40006-R0031479
Bid Name: Exterior Doors and Installation
Bid Opening Date: September 10, 2026

Addendum No: 1
Date Issued: August 27, 2026

This addendum is hereby officially made a part of the referenced solicitation. The below has been clarified as follows.

1. Due to manufacturer lead times, is it possible to extend the completion of 60 days to ensure the required materials, and the site work will be completed in a timely manner?
Yes, we can extend the time by 10 days to a total of 70 days.
2. Can you please clarify how power is intended to be run to the electrified door hardware?
The power is to be run in the frame through hinge pockets into door.
3. Should bidders assume the use of an Electric Power Transfer (EPT), or is another method anticipated?
Yes, the contractor is to provide and install the transfer box.
4. Is there existing electrical infrastructure in the door frames that is intended to be reused?
No. The contractor is to provide connection from the door hardware to the transfer box. Our electrician will connect to the contractor installed transfer box.

Acknowledgement: Acknowledgement of this addendum is mandatory.

Bidder shall acknowledge where indicated on the Bid Form or if your Bid has already been submitted, please sign below where indicated and email this form in its entirety to wboesc@dcc.edu it can also be mailed to the address stated on page 2 of the Bid Document. Whether indicated on the Bid Form, by email or mail, acknowledgement of this Addendum must be legible and received prior to the opening date and time indicated in the bid documents. **Failure to acknowledge and/or submit addendum by the bid due date and time will cause your bid to be disqualified.**

The below signed acknowledges receipt of this addendum.

Company: _____ Signature: _____

Printed Name: _____