



Division of Finance
Purchasing

ADDENDUM #1

September 9, 2026

RE: Bid Number 50012-661-27: Inspections and Preventative Maintenance of Building Generators

The following information is provided to amend the original invitation to bid on August 28, 2026.

- The original solicitation stated under Annual Inspection and Preventative Maintenance Requirements, 7. Coolant, a) Flush coolant and replace with proper coolant mixture with inhibitors, per manufacturer's guidelines. This requirement is hereby amended to indicate, a) Take a Coolant sample to ensure proper coolant mixture with inhibitors, per manufacturer's guidelines. If coolant replacement or addition is required, the University will provide the replacement coolant to the Awarded Vendor. The University will identify approximately twenty-five (25%) percent of Building Generators annually for the Awarded Vendor to provide a full coolant flush during the Annual Inspection. The University will provide the replacement coolant to the Awarded Vendor for this coolant flush. This listing of buildings will be provided to the Awarded Vendor by the University prior to the beginning of the Annual Inspection cycle.
- The original solicitation stated under Annual Inspection and Preventative Maintenance Requirements, 7. Coolant, c) Change all hoses and belts. This requirement is hereby amended to indicate, c) Inspect all hoses and belts for wear or damage. If hoses or belts require replacement, the Awarded Vendor shall provide a quotation to the University within seventy-two (72) hours indicating pricing of replacement products. The Awarded Vendor shall utilize the fixed hourly labor rate for normal business hours if the repair / replacement is approved by the University.

All other specifications remain unchanged.

Sincerely,

Clint Williams
Assistant Director of Purchasing
Louisiana Tech University
(318) 257-4205
clintw@latech.edu