



**Division of Finance
Purchasing**

ADDENDUM #2

October 1, 2026

RE: Bid Number 50012-664-27: Replace Chiller - Lomax Hall

The following information is provided to amend the original invitation to bid on September 9, 2026.

- **Please see the attached addendum provided by the designer.**

All other specifications remain unchanged.

Sincerely,

Clint Williams
Assistant Director of Purchasing
Louisiana Tech University
(318) 257-4205
clintw@latech.edu



CONSULTING ENGINEERS

**ADDENDUM #2
REPLACE CHILLER – LOMAX HALL
LOUISIANA TECH UNIVERSITY
RUSTON, LA 71270
BID NO. 50012-664-27
AFJMc PN 26-149**

October 1, 2026



THE FOLLOWING MODIFICATIONS AND/OR CLARIFICATIONS SHALL BE MADE TO THE DRAWINGS AND PROJECT MANUAL FOR THE CAPTIONED PROJECT:

MECHANICAL

DRAWINGS

1. Sheet ME1.02:
 - A. Refer to “LOMAX MECHANICAL ROOM – ELECTRICAL RENOVATION PLAN”
 1. Heat trace circuiting to be GFCI protected.
2. Sheet ME2.01:
 - A. Refer to “CHILLED WATER PIPING DIAGRAM”
 1. Change the pipe size of the cold water make up, backflow preventer and branch to boiler make up to 1 ¼” size.
 2. Provide a shut off valve and a check valve in each of the 1 ¼” make up lines to the chilled water system and the heating water system. Valves shall be downstream of the backflow preventer.

END ADDENDUM #1