



RECREATION AND PARK COMMISSION
FOR THE PARISH OF EAST BATON ROUGE

Addendum No. 2
Issued October 22, 2026

Sealed Bid No. 1878 – Melvin Kip Holden Pedestrian Bridge Improvements at Harding Blvd.

Submittal Deadline: 2:00 P.M. CT Tuesday November 3, 2026
Recreation and Park Commission for the Parish of East Baton Rouge (BREC)

The following items shall be considered part of the Contract Documents for the above referenced project and shall take precedence over any conflicting statements contained therein. Replace, revise, and/or add to all other specifications, notes, schedules, drawings, details, elevations, sections as required.

General Contractors are cautioned to bring to the attention of all subcontractors any changes which may affect their work.

The contractor shall acknowledge receipt of this addendum on the Louisiana Uniform Public Work Bid Form included in the Contract Documents.

The bid opening date for this project has been delayed by one week to allow more time for prospective bidders to plan for and coordinate access to the site. The new deadline to submit bids is **2:00 P.M. CT Tuesday November 3, 2026**.

REQUESTS FOR CLARIFICATIONS RECEIVED VIA EMAIL & RESPONSES:

- Does the concrete for the abutments need to meet surface resistivity?
 - The 1997 EBR Construction Specifications and the EBR Special Provisions do not provide concrete surface finish requirements. The only acceptance measures for the concrete are an approved mix design that is to be submitted prior to ordering the batch as well as 28-day breaks that show the required compressive strength.
- At the pre-bid, there was mention of quantities being adjusted. What is the status of that information?
 - This was addressed in Addendum #1
- Has BREC had any conversations with the home owners on the corner of 79th Ave and Emile St regarding access to the project from that street?
 - BREC has not had any contact with them.
- Will DOTD allow for a temporary lane closure of the I-110 entrance ramp immediately adjacent to the project for off-loading material at the project site?
 - DOTD has stated that they will not allow closure of the ramp on discussions that BREC has with them.
- The plans dictate access from the NW along the existing sidewalk. This sidewalk is in bad condition and any construction traffic would make this worse. This being the case, would the contractor be required to mat over the existing sidewalk?



RECREATION AND PARK COMMISSION
FOR THE PARISH OF EAST BATON ROUGE

- The contractor shall preserve the site conditions as they are and repair any damages as a result of construction, access, or otherwise related to or a consequence of any work on this project. Any contractor may utilize matting at their discretion as part of their means and methods.
- Is there a possibility of postponing this bid one week? The access component of this project is extremely difficult and I think the extra time would allow for better planning.
 - The bid deadline has been extended by one week.

If you have already submitted your proposal and this addendum causes you to revise your original submittal, please indicate changes herein and return to Purchasing prior to the proposal deadline in an envelope marked with the RFP number, proposal deadline date and time. **Please acknowledge receipt of the addendum by signing your name and company below and returning it in accordance with the provisions above.**

(Name and Signature)

(Date)

(Company Name)